

# Works Certificate

in accordance with DIN EN 10204: 2005-01



A Phoenix Mecano Company

IP Protection Test according to VDE 470 Teil 1 - DIN EN 60529: 2014-09

Cerificat-No.: 687

Test-No.: 1073

Date: 18.08.2016

by order of: Bopla Gehäuse Systeme GmbH

## test items

item number:

Product group: 20

BCD 160 (200, 250, 310, 400) UT - . . . . .

or

BCD 160 (200, 250, 310, 400) UT-0,5 - . . . . .

in combination with:

BCD 160/165 (200/205, 250/255, 310/315, 400/405) OT-G - . . . . .

or

BCD 160/165 (200/205, 250/255, 310/315, 400/405) OT-FSC - . . . . .

## form of testing / result:

IP 66 / IP 68 - 1,2m (2 hours)

test passed

remarks: foamed standard seal in the lid

Test executed by:

18.08.2016

P. Hemeier

controlled:

18.08.2016

A. Krömer

use: internal:  external:

Attachment: